

A decorative graphic consisting of a thin gold circle. A thick black left square bracket is positioned on the left side of the circle, and a thick gold right square bracket is on the right side. A horizontal gold bar is centered across the circle, containing the product name.


# Dais-Analytic High Latent Fixed Plate Energy Recovery Ventilator

Dais-Analytic Corp

# What is Energy Recovery Ventilation?

- Preconditioning of fresh outside air by using exhaust (return air) from a building
- Air to air energy exchange
- Typical types of ERV:
  - Enthalpy wheels
  - Heat pipes
  - Fixed plate heat exchangers

# Heat Exchanger: Used to Precondition Outside Air




## **Dais Analytic Membrane Core**


The heart of the system.  
The membrane energy recovery core has both sensible and latent transfer.

- Pre-Cools air during the summer
- Pre-Heats air during the winter

# Typical Installations



# Decoupled from Packaged Rooftop




# [ ERV Benefits ]

---

- Reduces building loads
  - 1/3 can be loads due to conditioning OA
  - Saves \$
  - Allows for downsizing other HVAC equipment
  - Saves peak KW and KWH
- Controls moisture in buildings (if using ERV that can transfer latent)

# Demand Savings(kW) Projection – Walmart


Ventilation Electrical Demand Savings



Ventilation Peak Demand = 14kW  
MERV Ventilation Peak Demand = 5kW  
Peak Demand Savings = 9kW 64%

# Energy Savings (kWh) Projection – Wal-Mart

## Ventilation Electrical Energy Savings




Ventilation Energy = 19,640kWh  
MERV Ventilation Energy = 16,781kWh  
Total Energy Savings = 2,859kWh 15%



# Therm Savings Projection – Wal-Mart

Ventilation Therm Savings




Ventilation Therms = 3922 therms  
MERV Ventilation Therms = 980 therms  
Total Therm Savings = 2,942 therms 75%

# [ Downsizing HVAC Plant ]

- Conditioning of outside air can account for up to 1/3 of a building's cooling load
- Load is reduced by using ERV
- Example:
  - AC plant reduced from 40 ton load to 30 tons
  - At \$500/ton AC installed cost
  - Owner saves \$5,000 towards first cost of AC

# Downsizing Cooling Equipment Using Dais ERV

## Preconditioning Lowers Chiller Size



\* Presented by United Technologies/Carrier to the US Environmental Protection Agency January 2002

# [ Typical School Downsizing Savings ]

- Elementary school
- Originally designed at 345 tons
- Using ERV with 65% total effectiveness
  - Reduced load by 85 tons
  - Payback 2.2 years


# Moisture Control at Part Load

**Outside Air @ 82 db, 75 rh,  
105 grains**

**78 db, 62%, 94 grains**

**Return Air @ 77 db,  
47%, 65 grains**

**Air to Building @ 78  
db, 67%, 92 grains**




# [ ERV Technology Comparisons ]

---

# [ Types of ERV ]



Enthalpy wheels: good moisture transfer, higher cost, maintenance



Heat pipes: metal pipes carrying refrigerant, no moisture transfer, sensible only

Fixed plate exchangers: sensible only until now, low cost and maintenance



[ So, what's different? ]

---

- FIXED PLATE Energy Recovery Ventilator
  - High Latent
  - High Sensible
- No rotating parts or excess energy required
- Better peak energy reduction
- Fixed plate has inherently low or no leakage between airstreams
- Energy transfer is in the vapor state - No condensation or drain pans required



# Hi Latent Fixed Plate Installation

**Heat and  
moisture  
exchange in a  
fixed plate**

In the vapor state;  
no moisture  
collection in unit



# [ Advantage Over Enthalpy Wheels ]

- No rotating parts
- Better part load performance
- Less energy and demand usage
- Nothing to “break”
- Failsafe for downsizing HVAC plant – the air flows through the same paths always
- No/low leakage between airstreams

# Effectiveness Ratings of ERV Technologies

(Component Testing at ARI Standard 1060 Conditions, June 2002)

Effectiveness	Enthalpy Wheel	Heat Pipes	Other Fixed Plate	<b>Dais ERV</b>
Sensible (Summer Conditions)	75%	45%	75%	<b>75%</b>
Latent (Summer Conditions)	70%	0%	25%	<b>75%</b>
Sensible (Winter Conditions)	75%	50%	78%	<b>77%</b>
Latent (Winter Conditions)	70%	0%	28%	<b>75%</b>

*The membrane ERV has the effectiveness of an enthalpy wheel with no moving parts!*

# Monitoring of Various ERV Technologies - Field Installation



## ERV Monitoring - Sunray Elementary School

New Port Richey, FL 450 CFM ERV

Based on Normalized Outside Air Enthalpy(40.58 Btu/lb)

	Max Temp Reduction Across Unit	Max Enthalpy Reduction Across Unit	Tons Saved	Peak Kw Saved
Wheel Type ERV	6.46	6.11	1.38	0.16
Fixed Plate ERV	6.53	5.09	1.00	0.57
Membrane ERV	8.10	7.37	1.42	0.99


OA enthalpy equivalent to approximately 85 deg F and 60% rh

# Monitoring of Various ERV Technologies - Field Installation




	KW/Ton Cooling Measured
Wheel Type ERV	0.88
“Sensible” Fixed plate ERV	0.45
Dais-Analytic Fixed Plate ERV	0.32

# [ Downsizing Risk Using Wheels ]



# “No Risk” Downsizing

- No rotating parts required for heat exchange – no failure mode
- Air will always proceed in the same path



**Dais Analytic Membrane Core**  
The heart of the system.  
The membrane energy  
recovery core has both  
sensible and latent transfer.

# [ Performance of Dais Analytic ]


## Laboratory

- Air Conditioning and Refrigeration Institute (ARI) lab
- National Renewable Energy Lab (NREL)  
– part of DOE
- In House

## Field Trials



# Performance Ratings at ARI conditions 9000 cfm rated (ZERO Leakage)



# Performance at ARI Conditions


(psych chart)

**Outside Air @ 95 db, 78  
wb, 118 grains**

**Exhaust Air 90 db, 67  
wb, 83 grains**

**Return Air @ 75 db, 63  
wb, 67 grains**


**Air to Building @ 80  
db, 74 wb, 102 grains**



# Field Installations

- Retail store: Wal-Mart - Mason City, Iowa (Alliant utility)
- Office Building – Omaha, Nebraska (OPPD utility)
- Office Building – Daytona, Florida (FPL utility)
- Office Building – San Jose, Costa Rica
- Elementary School – Pasco County, Florida (FPC utility)
- Manufacturing Facility – Madison, Wisconsin
- Brie's Restaurant – New Port Richey, Florida
- Aspasia Salon – New Port Richey, Florida
- Residence – Largo, Florida
- Subway Restaurant – Brandon, Florida (pending) (TECO utility)
- Retail store: Walgreens – St. Petersburg, Florida (pending)


# [ Monitoring ]



- Based on ARI 1060 Standard
- Measure: Heat transfer across core
- Measure: Total electric usage of unit

# Monitoring

- To validate the savings this system will be monitored using temperature, humidity, and power metering equipment.



# Monitoring Challenges in the Field

- Non steady-state conditions
  - Outside air stream temperature/humidity fluctuations
  - Indoor air control conditions fluctuations
- Condensate may form on sensors
- Sensor location may not be ideal
- Air flow measurement using commercial sensors
- Building and data access

# FP&L Installation

- Daytona Office, Florida
- Rooftop mounted
- Reduced 7.65 tons in 2500 OA cfm
- Used 1.98 KW of power for blowers
- Cooling capacity provided by unit  
 $1.98 \text{ KW} / 7.65 \text{ tons} = .26 \text{ kw/Ton}$   
(no compressor)



- **SHOWS EXCEPTIONAL MOISTURE AND HEAT TRANSFER**
  - **ESPECIALLY AT MILD OUTSIDE AIR TEMPERATURE CONDITIONS**


- **THE DOWNSTREAM DRAIN PANS ON THE AIR HANDLING UNITS ARE DRY**

# FPL Installation – at “Mild Temp” (Stop Mold Problems BEFORE they start) Part Load Performance


## Outside Air System

**Systems Control**


	1st Floor	2nd Floor
Current Flow	1087.02 cfm	1313.72 cfm
CO2 Level	648.66 ppm	659.66 ppm
Max CO2 Setpoint	1100.00 ppm	1100.00 ppm




1st Floor Standard





1st Floor ERV Unit






2nd Floor Standard



2nd Floor ERV Unit

 1st Floor RR Fan  
 1st Floor Inline Fan

 2nd Floor RR Fan  
 2nd Floor Inline Fan  
 2nd Floor Plenum Fan


Fan / Damper Control

**Energy Recovery Ventilation System Performance Data**

Recovered Tons from Exhaust Air:	3.86 tons
Moisture Removed from Supply Air:	32.63 lb/hr
Fan Energy Used:	1.93 kW
Measured Outside Supply Air Flow Rate:	10427.97 lb/hr
Calculated Exhaust Air Flow Rate:	9468.10 lb/hr
Energy Efficiency Ratio:	23.94 EER
Outside Air Temp (Weather Station):	82.00 °F
Decrease of OA Supply Dry Bulb Temp:	4.00 F
Decrease of OA Supply Absolute Humidity:	20.89 %
Recovered Tons (% of Building Load):	16.17 %

**Outside Air**  
 82.00 °F  
 63.82 %RH  
 72.51 WB  
 36.12 BTU/lb.  
 0.35 psia  
 104.87 gr.  
 13.98 cf/lb.

**Exhaust Air**  
 77.10 °F  
 46.71 %RH  
 63.31 WB  
 28.64 BTU/lb.  
 0.22 psia  
 64.79 gr.  
 13.73 cf/lb.



**Relief Air**  
 78.30 °F  
 64.82 %RH  
 69.54 WB  
 33.53 BTU/lb.  
 0.31 psia  
 94.29 gr.  
 13.86 cf/lb.


**Supply Air**  
 78.00 °F  
 57.71 %RH  
 67.30 WB  
 31.68 BTU/lb.  
 0.27 psia  
 82.97 gr.  
 13.81 cf/lb.



# [ Part Load Performance (psych chart) ]

**Outside Air @ 82 db, 75 rh,  
105 grains**

**78 db, 62%, 94 grains**



**Return Air @ 77 db,  
47%, 65 grains**

**Air to Building @ 78  
db, 67%, 92 grains**

# [ Wal-Mart Field Installation ]

---

- Install 2 MERV units (3400 cfm) at retail customer in Mason City, IA.
- 24 hour facility
- Customer does NOT currently incorporate ventilation energy recovery – provides new opportunity for savings
- Monitor to assure savings

# WAL-MART CORPORATION, IOWA

Large retail  
2 ERV units  
3400 CFM total



## Data Points at Various Outside Air Conditions

		Fresh Air IN	Fresh Air IN	Fresh Air OUT	Fresh Air OUT	Exh. Air IN	Exh. Air IN	Exh. Air OUT	Exh. Air OUT	Fresh Air
Date	Time	Temp	RH	Temp	RH	Temp	RH	Temp	RH	Flow
		[deg. F]	[%]	[deg. F]	[%]	[deg. F]	[%]	[deg. F]	[%]	[cfm]
12/5/2002	7:45	6.77	61.63	43.5	14.8	65.1	10.54	18.33	56.55	1848
12/4/2002	9:50	25.03	71.6	53.26	23.44	67.18	16.26	34.27	55.83	1788
12/9/2002	12:50	40.28	32.2	60.7	14.44	68.64	14.1	46.79	31.19	1705
12/14/2002	15:35	54.27	38.97	67.43	23.47	70.6	24.58	59.07	36.06	1599
8/29/2002	14:50	83	46.5	78.1	49.02	72.1	48.9	82.6	39.24	1719
8/26/2002	15:30	85.2	50.05	78.9	53.42	72.4	52.12	84.3	41.44	1713

# [ Maintenance ]


---

- Filters recommended for inlet airstreams
- Vacuum face of core twice per year to remove particulate
- Cores slide in and out for maintenance or inspection

# [ Offices ]



# [ Schools ]



# [ Wal-Mart ]





# [ Subway ]





# [ Walgreens ]

---

